

क्र.: रटामराकौवि/पुणे/UPS- Des Lab/२०२६-२७/369

दिनांक : 22 JUL 2026

दरपत्रक सुचना

विषय: विद्यापीठाच्या पुणे केंद्रातील B. Design संगणकांकरिता UPS व Battery खरेदी करणेबाबत.

रतन टाटा महाराष्ट्र राज्य कौशल्य विद्यापीठ, मुंबई यांचे कार्यालय एल्फिन्स्टन महाविद्यालय येथे सुरु करण्यात आले आहे. रतन टाटा महाराष्ट्र राज्य कौशल्य विद्यापीठ अंतर्गत पिंपळे गुरव, पुणे येथे कुलगुरू यांच्या मान्यतेनुसार B. Design संगणकांकरिता UPS व Battery खरेदी करणे प्रस्तावित आहे.

उपरोक्त UPS व Battery खरेदीकरिता मा. कुलसचिव, रतन टाटा महाराष्ट्र राज्य कौशल्य विद्यापीठ, मुंबई यांच्या नावे संस्था/ कंत्राटदार यांचेकडून सीलबंद दरपत्रके मागवण्यात येत आहेत.

सदर दरपत्रके दिनांक 39/07/२०२६ दुपारी ३.०० वाजेपर्यंत रतन टाटा महाराष्ट्र राज्य कौशल्य विद्यापीठ, काशिद नगर, राजमाता जिजाऊ उद्यान जवळ पिंपळे गुरव पुणे या कार्यालयात पोहोचतील अशा पद्धतीने पाठविण्यात यावीत. उशिरा आलेली दरपत्रके स्वीकारण्यात येणार नाहीत.

सोबत जोडलेल्या (Annexure) दरपत्रकामध्ये दर नमुद करताना ते सर्व करासहित, वाहतुक खर्च, लोडिंग अनलोडिंग व इतर तत्सम खर्चासह असावेत अथवा त्यामध्ये याबाबत स्पष्ट उल्लेख असावा तसेच सीलबंद पाकिटावर करावयाच्या कामाच्या बाबीचा आणि दरपत्रक सादरीकरणाच्या अंतिम दिनांकाचा स्पष्ट उल्लेख असावा.

प्राप्त झालेल्या दरपत्रकांपैकी काही अथवा सर्व दरपत्रके नाकारण्याचा अधिकार राखून ठेवण्यात आला असून याबाबतचे कोणतेही कारण देणे बंधनकारक नाही.

प्राप्त झालेल्या दरापैकी कमी असलेल्या दरास काम देण्यात येईल. सदर काम द्यावयाचे सर्व अधिकार मा. कुलसचिव, रतन टाटा महाराष्ट्र राज्य कौशल्य विद्यापीठ, मुंबई यांनी राखून ठेवले आहेत.





डॉ. वैभव नरवडे,
(कुलसचिव)
र.टा.म.रा.कौ.वि. मुंबई

Ratan Tata Maharashtra State Skills University, Mumbai

Details of required online UPS and Batteries

(Annexure1)

Sr. No.	Particulars	Rate in Rs	Amount in Rs
1	UPS On-Line, 10kVA		
	Main Input Voltage	230 V AC 1 phase	
	Input voltage	220 V /240 V	
	Input voltage limits	110...300 V 60 % load 176...300 V full load	
	Number of input connectors	1 hard wire 3-wire (1P + N + E)	
	Network frequency	40...70 Hz auto sensing	
	Output voltage	230 V AC 1 phase	
	Output voltage	220 V/240 V	
	Rated power in W	10000 W	
	rated power in VA	10000 VA	
	Output connector type	Hard wire 3-wire (1P+N+ E) for 1 zone(s)	
	Bypass type	Internal bypass (automatic and manual)	
	Crest factor	3:1	
	Maximum configurable power in	10000 VA/ 10000 W	
	UPS type	On-Line	
	Wave type	Sine wave	
	Efficiency	94 % (full load)	
	Output frequency	50/60 Hz +/- 3 Hz sync to mains	
	Control panel	Multifunction LCD status and control console	
	Emergency power off	Yes	
	Free slots	1	
	Alarm	Yes	
	UPS connectivity	Serial port / USB port / Available expansion slot	
	Surge energy rate	600 J	
	Number of rack unit	2U	
	Height	86.5 mm	
	Width	438 mm	
	Depth	615 mm	
	Warranty (in months)	24	
2	Battery Details		
	12V 26 Ah, Size: 199*165*181		
	Operating Temperature Range	0°C -45°C	
	Ah Efficiency	>90%	
	Wh Efficiency	>80%	
	Temperature Compensation	- 18mV/ °C / 12V Unit	
	Self-Discharge Per month	<3%	
	Lead-tin-calcium Alloy plates		
	Low resistance micro porous glass fiber separator		
	Self-regulating pressure relief valve		
3	Rack and Interlink		
Total			
GST			
Total including GST			



Kindly note:

1. Gst certificate of proprietor/owner of company.
2. Average Turnover certificate with UDIN for last 3 year with average Turnover as 10lakhs.
3. Similar Workdone certificate and completion certificate from govt/semi govt-(similar work done workorder value should be 80% of tender amount).
4. Solvency certificate of 10 lakhs from scheduled banks letterhead for current financial year.
5. MSME Certificate.
6. Cost should be inclusive of installation, transportation, loading unloading charges.
7. The prices listed for the aforementioned goods are good for six months after the work order data.
8. Delivery/ Installation/Service address: RTMSSU, smart centre building, opposite Rajmata Jijau Marg, Kashid Nagar, Pimple Gurav, Pimpri-Chinchwad, Maharashtra 411061.
9. PAN details, any other Certification / license attach with quotation.



Dr. Vaibhav Narawade
(Registrar)
RTMSSU, Mumbai